



EVPÜ[®]

CERTIFICATE

No. 00026/101/1/2010

on 9. february 2010

Applicant

Notifier Italia S.r.l.

Via Grandi, 22 - 20097 San Donato Milanese (MI), Italy

Manufacturer

Notifier Italia S.r.l.

Via Grandi, 22 - 20097 San Donato Milanese (MI), Italy

Product

Analog Addressable Fire Detection Panel

Type

AM-4000

Specifications

230 V~, 50/60 Hz, 0.6 A

The sample meets the essential safety requirements of the following Directives of EP and Council transposed into "Slovak government decrees" as amended:

LVD Directive 2006/95/EC

GD SR 308/2004 Coll. of Laws

EMC Directive 2004/108/EC

GD SR 194/2005 Coll. of Laws

A sample of the product was tested and found to be in conformity with following standards and / or technical specifications applied:

EN 60950-1: 2006 + A11: 2009

EN 55022: 2006 + A1: 2007

EN 61000-3-2: 2006

EN 61000-3-3: 2009

EN 50130-4: 1995 + A1: 1998 + A2: 2003

Results of tests and examinations of the conformity of features of mentioned product type are stated in Final report No. 00034/2010/C on **February 9, 2010**.

Certificate confirms that the equipment complies with the Essentials requirements and purpose of use mentioned in Directives of EP and Council / standards.

Certificate is valid until : **February 8, 2013**

Ing. Karol G l a m o š



Marking may only be used if all relevant and effective Directives of EP and Council are complied with.

Any significant changes in the design or construction of the products, the quality system and amendments of the technical and legal decrees reference above may tender this Certificate invalid. The product liability rests with the manufacturer or his representative.

032183

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk