

Loss Prevention Certification Board



This is to certify

KAC ALARM COMPANY LIMITED

15-19 Trescott Road, Trafford Park, Smallwood,
Redditch, Worcestershire, B98 7AH

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

**MCP5A-RP02xx, MCP5A-RP04xx, WCP5A-RP02Sx
and WCP5A-RP04Sx manual call points**

(refer to attached appendix for details)

which have complied with the requirements of the following:

**EN 54-11: 2001 - Fire detection and fire alarm systems -
Manual Call Points**

**EN 54-17: 2005 - Fire detection and fire alarm systems -
Short-circuit isolators**

Certificate No. 166e

Issue No. 01

Date of Issue 14 July 2006

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: E MATTIE-SULEIMAN



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 166e

KAC ALARM COMPANY LIMITED

Products

LPCB Ref. No.

MCP5A-RP02xx	Indoor/Outdoor surface/flush mounting addressable call point with short circuit isolator (System Sensor 500 series protocol)	166e/01
MCP5A-RP04xx	Indoor/Outdoor surface/flush mounting addressable call point with short circuit isolator (Honeywell 500 series protocol)	166e/02

Notes: 1. *Sx* (Surface mounted) *Fx* (Flush mounted)
2. *xG* (Glass element) *xF* (Flexible element)
3. The above manual call points are approved with three micro-switches (Honeywell ZM10E50A01, Otehall 294/20/150/G and Burgess X4G310K1BBAQ)

WCP5A-RP02Sx	Outdoor surface mounting addressable waterproof call point (System Sensor 500 series protocol)	166e/03
WCP5A-RP04Sx	Outdoor surface mounting addressable waterproof call point (Honeywell 500 series protocol)	166e/04

Notes: 1. *G* (Glass element) *F* (Flexible element)
2. The above waterproof manual call points are approved with Honeywell micro switch ZW10F90AW1

Accessories:

SR	Surface mounting plastic box
SR1T	Surface mounting plastic box c/w 1 terminal
SR2T	Surface mounting plastic box c/w 2 terminals
SR3T	Surface mounting plastic box c/w 3 terminals
SR4T	Surface mounting plastic box c/w 4 terminals
MR	Surface mounting metal box
ETT	European Terminal Tray ETT1, 2 & 3
L	Earth Continuity Link
BZR/1	Bazel Type 1
BZR/2	Bazel Type 2
BZR/3	Bazel Type 3
M141	Spacer Piece
PTR	Pattress PTR, PTRE, PTR2T, PTR2TE, PTR3T & PTR3TE
C	Hinged Cover

For details of Cross-Listed products and alternative branding please see page 3.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 2 of 3

Date of Issue 14 July 2006

Issue No. 01

Name: E MATTIE-SULEIMAN

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 166e

KAC ALARM COMPANY LIMITED

LPCB Ref. No.	Model No.	Alternative Model No.	Labelled
166e/01	MCP5A-RP02xx	MUS5A-RP02xx	KAC Alarm Company Ltd
166e/01	MCP5A-RP02xx	M700KACI-xx	Notifier Fire Systems
166e/02	MCP5A-RP04xx	MUS5A-RP04xx	KAC Alarm Company Ltd
166e/02	MCP5A-RP04xx	MI-MCP-xxxx-I	Morley-IAS

For details of Cross-Listed products and alternative branding please see page 3.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 3 of 3

Date of Issue 14 July 2006

Issue No. 01

Name: E MATTIE-SULEIMAN

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.